

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 1775

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Pearl Two loop analogue addressable control and indicating equipment for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

Pittway Systems Technology Group Europe Limited Trading as "Notifier By Honeywell"
Charles Avenue, Burgess Hill, West Sussex, RH15 9UF

and produced in the factory

Novar Systems Limited. Trading as "Gent by Honeywell"

140 Waterside Road, Hamilton Industrial Park, Leicester, LE5 1TN, United Kingdom


is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Global Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

EN 54 - 2: 1997 + A1: 2006 - Control and indicating equipment
EN 54 - 4: 1997 + A1: 2002 - Power supply equipment

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 12/03/2012 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 2/1/2013
Issue Number: 3
Page: 1 of 3

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 1775

The details and conditions of use for the Pearl Two loop analogue addressable control and indicating equipment, placed on the market by Pittway Systems Technology Group Europe Limited Trading as "Notifier By Honeywell" Charles Avenue, Burgess Hill, West Sussex, RH15 9UF are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Incorporating the following units:

772489-NE CPU board
124-408 3A PSU board
124-412 Network gateway module
124-421 Base board incorporating two loops (applicable on two loop version only)
124-421-001 Single loop base board incorporating one loop (applicable on one loop version only)
124-422 Display board
124-423 VdS I/O Module
124-426 Communications module
PRL-Box Extended Back box

Incorporating the following optional regional language text inserts:

PRL-LED-EN (English) applicable on two loop version only
PRL-LED-EN-1 (English) applicable on one loop version only
PRL-D (German)
PRL-IB (Iberia)
PRL-BNL (Benelux)
PRL-LCD-NRD (Swedish) applicable on two loop version only
PRL-LCD-NRD-1 (Swedish) applicable on one loop version only
PRL-MEA (Middle East and Africa)
PRL-IT (Italian)

Certified with the following options with requirements from EN 54-2:

7.8 Output to fire alarm devices
7.9.1 Output to fire alarm routing equipment
7.9.2 Alarm confirmation input from fire alarm routing equipment
7.10.1 Output to fire protection equipment type A
7.10.3 Output to fire protection equipment type C
7.10.4 Fault monitoring of fire protection equipment
7.11 Delays to outputs
7.12.2 Dependency on more than one alarm signal type B
7.12.3 Dependency on more than one alarm signal type C
7.13 Alarm counter
8.3 Fault signals from points
8.9 Output to fault warning routing equipment
9.5 Disabling of addressable points
10 Test condition



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 2/1/2013
Issue Number: 3
Page: 2 of 3

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 1775

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.
2. Scope of approval does not include the operation of the network functionality.

Variants:

Pearl One loop analogue addressable control and indicating equipment



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 2/1/2013
Issue Number: 3
Page: 3 of 3

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.