


Loss Prevention Certification Board



This is to certify

PITTWAY TECNOLOGICA SRL
Via Caboto 19/3, 34147 Trieste, Italy

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

2251CTLE
multi-criteria detector
(refer to attached appendix for details)

which has complied with the requirements of the following:

LPS 1279 – 1.0: 2006 – Testing Procedures for the LPCB Approval and Listing of Point Multisensor Fire Detectors using Optical or Ionization Smoke Sensors and Electrochemical Cell CO Sensors and, optionally, Heat Sensors.

EN 54-7: 2000 + A1: 2002 – Fire detection and fire alarm systems - Smoke detectors - Point detectors using scattered light, transmitted light or ionization.

EN 54-5: 2000 + A1: 2002 – Fire detection and fire alarm systems - Heat detectors: Point detectors.

CEA 4021: 2003 – Specifications for fire detection and fire alarm systems - Requirements and test methods for multisensor detectors, which respond to smoke and heat, and smoke detectors with more than one smoke sensor.

Certificate No. 199t


Issue No. 03

Date of Issue 29 August 2008

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB


Name:  N. DANIEL



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 199t

PITTWAY TECNOLOGICA SRL

Products

LPCB Ref. No.

2251CTLE Analogue addressable multi-criteria fire detector incorporating CO, photoelectric, thermal and IR sensors (B501, B501AP, B501DG and B524IEFT-1 bases)

199t/01

Note: Certified at the following settings: -

Normal Mode: Alarm Levels 1 to 5 (Multi-criteria): EN54-5 Class A1R, EN54-7, LPS1279 and CEA 4021
Alarm Level 6 (Heat Only Mode): EN54-5 Class A1R

Nuisance Environment Applications:

Application 0, Alarm Level 4	EN54-7, LPS1279 & CEA 4021
Application 1, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021
Application 2, Alarm Level 4 or 5	EN54-5 Class A1R, EN54-7 & CEA 4021
Application 3, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021
Application 4, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021
Application 5, Alarm Level 5	EN54-7 & CEA 4021
Application 6, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021

Bases:

B501 Analogue detector base
B501DG Analogue deep detector base
B524IEFT-1 Analogue short circuit isolator base
B501AP Intelligent detector base

For details of Cross-Listed products and alternative branding please see page 3

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 2 of 3

Date of Issue 29 August 2008


Issue No. 03


Name: N DANIEL

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 199t

PITTWAY TECNOLOGICA SRL

ALTERNATIVE MODEL NUMBERS AND LABELLING

LPCB Ref No.	Model No.	Alternative Model No.	Labelled	Distributor's Cert /Ref No.
199t/01	2251CTLE	IRX-751CTEM 2251CTLEJ ESMI2251CTLE TC850E1009	Notifier Fire Systems Johnson Controls OY ESMI AB Honeywell Control Systems	199t/01 199t/01 199t/01 199t-(cl-1)

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 3 of 3

Date of Issue 29 August 2008

Issue No. 03


Name: N DANIYEL

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.