

CERTIFICATE

of constancy of performance

1922 - CPR - 1833

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Smoke alarm devices. Smoke detector.
Models: Ajax FireProtect and Ajax FireProtect Plus.
Intended use: Fire safety

(with the performance listed, see Annex I to 1922-CPR-1833 that is an inseparable part of this certificate)

placed on the market under the name or trade mark of
AJAX SYSTEMS CYPRUS HOLDINGS LTD
Ifigeneias, 17, Strovolos, 2007, Nicosia, Cyprus
and produced in the manufacturing plant
001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14604:2005; EN 14604:2005/AC:2008

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 15.07.2022 and will remain valid until 15.07.2025 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager:

Anna Vasileva

Issued:
Burgas, 15 July 2022

Ref. No. 01-00

dipl. eng. Anna Vasileva

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1833/15.07.2022 PAGE 1/2

Performance list, acc. to EN 14604:2005; EN 14604:2005/AC:2008

Essential Characteristics	Performance	Clause
Nominal activation conditions / sensitivity / Response delay (response time) and performance under fire conditions		
- Smoke alarm signals	Pass	4.12
- Inter-connectable smoke alarms	N/A	4.18
- Repeatability	Pass	5.2
- Directional dependence	Pass	5.3
- Initial sensitivity	Pass	5.4
- Air movement	Pass	5.5
- Dazzling	Pass	5.6
- Fire sensitivity	Pass	5.15
- Sound output	Pass	5.17
- Sounder durability	Pass	5.18
- Inter-connectable smoke alarms	N/A	5.19
- Alarm silence facility	Pass	5.20
Operational reliability		
- Compliance	Pass	4.1
- Individual alarm indicator	Pass	4.2
- Mains-on indicator	N/A	4.3
- Connection of external ancillary devices	N/A	4.4
- Means of calibration	Pass	4.5
- User replaceable components	Pass	4.6
- Normal power source	Pass	4.7
- Standby power source	N/A	4.8
- Electrical safety requirements	Pass	4.9
- Routine test facility	Pass	4.10
- Terminals for external conductors	N/A	4.11
- Battery removal indication	Pass	4.13
- Battery connections	Pass	4.14
- Battery capacity	Pass	4.15
- Protection against the ingress of foreign bodies	Pass	4.16
- Additional requirements for software controlled smoke alarms	Pass	4.17
- Marking and data	Pass	4.19
- Impact	Pass	5.11
- Battery fault warning	Pass	5.16
- Battery reversal	Pass	5.22
- Back-up power source	N/A	5.23
- Electrical safety – assessment and testing to determine the adequacy of personal protection against hazardous currents passing through the human body (electric shock), excessive temperature and the start and spread of fire	Pass	5.24



Manager:

Anna Vasileva

Issued:
Burgas, 15 July 2022

Ref. No. 01-00



dipl. eng. Anna Vasileva

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1833/15.07.2022 PAGE 2/2

Performance list, acc. to EN 14604:2005; EN 14604:2005/AC:2008

Essential Characteristics	Performance	Clause
Tolerance to supply voltage		
- Variation in supply voltage	Pass	5.21
Durability of operational reliability and response delay, temperature resistance		
- Dry heat	Pass	5.7
- Cold (operational)	Pass	5.8
Durability of operational reliability, vibration resistance		
- Vibration (operational)	Pass	5.12
- Vibration (endurance)	Pass	5.13
Durability of operational reliability, humidity resistance		
- Damp heat (operational)	Pass	5.9
Durability of operational reliability, corrosion resistance		
- Sulphur dioxide (SO ₂) corrosion	Pass	5.10
Durability of operational reliability, electrical stability		
- Electromagnetic compatibility (EMC), immunity (operational)	Pass	5.14

This certificate was first issued on 15.07.2022 and will remain valid until 15.07.2025 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager:

Anna Vasileva



dipl. eng. Anna Vasileva

Issued:
Burgas, 15 July 2022

Ref. No. 01-00